



ELECTRICAL INSTALLATION CONDITION REPORT

(REQUIREMENTS FOR ELECTRICAL INSTALLATIONS
— BS 7671 [IET WIRING REGULATIONS])

SELECT
MEMBERSHIP
NUMBER
23095

This certificate is not valid if the
number is defaced or altered

EICR 251161

Copyright © The Electrical Contractors' Association of Scotland

SECTION A. DETAILS OF THE PERSON ORDERING THE REPORT

Name: DAVID GARDINER

Address:

SECTION B. REASON FOR PRODUCING THIS REPORT

Reason: TO ESTABLISH AS FAR AS REASONABLY PRACTICABLE THE INSTALLATION IS SAFE FOR CONTINUED USE Date(s) on which inspection and testing was carried out:

SECTION C. DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier: VOID

Address: 169 CAIM STREET, HAMILTON, ML3 0AZ

Description of premises (Tick as appropriate): Domestic Commercial Industrial Other

Estimated age of the wiring system: years. Evidence of additions or alterations Yes No Not apparent

If "Yes" estimate age: years. Installation records available? (Regulation 651.1) Yes No Date of last inspection:

SECTION D. EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of the electrical installation covered by this report: FULL ELECTRICAL INSTALLATION

Agreed limitations including the reasons (Regulation 653.2): N/A

Agreed with (name): N/A

Operational limitations including the reasons: LIVE TESTING OF OFF PEAK CIRCUITS OFF PEAK OF

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2018 (IET Wiring Regulations), as amended to 2020. It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground have **not** been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SECTION E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): GENERALLY IN GOOD CONDITION
C.3'S NEED ATTENTION

Overall assessment of the installation in terms of its suitability for continued use

SATISFACTORY / UNSATISFACTORY (Delete as appropriate)

*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

SECTION F. RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (code F1). Observations classified as 'Improvement recommended' (code C3) should be given due consideration.

Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

SECTION G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in Section D of this report.

Inspected and tested by:

Name (Capitals) ALAN BAIRD

Signature [Signature]

For/on behalf of W.B. ELECTRICAL SERVICES

Position APPROVED ELECTRICIAN

Address UNIT 3 17A HARELDSHILL ROAD LANARK

Date 14/06/21

Report authorised for issue by:

Name (Capitals) ALAN BAIRD

Signature [Signature]

For/on behalf of W.B. ELECTRICAL SERVICES

Position APPROVED ELECTRICIAN

Address UNIT 3 17A HARELDSHILL ROAD LANARK

Date 14/06/21

SECTION H. SCHEDULE(S)

..... schedule(s) of inspection and schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

SECTION I. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements	Number and Type of Live Conductors	Nature of Supply Parameters	Supply Protective Device Characteristics
TN-C <input type="checkbox"/> TN-S <input type="checkbox"/> TN-C-S <input checked="" type="checkbox"/> TT <input type="checkbox"/> IT <input type="checkbox"/>	AC <input checked="" type="checkbox"/> DC <input type="checkbox"/> 1-phase, 2-wire <input checked="" type="checkbox"/> 2-wire <input type="checkbox"/> 2-phase, 3-wire <input type="checkbox"/> 3-wire <input type="checkbox"/> 3-phase, 3-wire <input type="checkbox"/> Other <input type="checkbox"/> 3-phase, 4-wire <input type="checkbox"/>	Nominal voltage, $U/U_0^{(1)}$ <u>230</u> V Nominal frequency, $f^{(1)}$ <u>50</u> Hz Prospective fault current, $I_{pf}^{(2)}$ kA External loop impedance, $Z_e^{(2)}$ Ω	BS (EN): <u>1361</u> Type: <u>Tb</u> Rated current: <u>LIM 100</u> A
Confirmation of supply polarity <input type="checkbox"/>		(Note: (1) by enquiry, (2) by enquiry or by measurement)	
Other sources of supply <input type="checkbox"/> (as detailed on attached schedule)			

SECTION J. PARTICULARS OF INSTALLATION REFERRED TO IN THE REPORT

Means of Earthing	Details of Installation Earth Electrode (where applicable)		
Distributor's facility <input checked="" type="checkbox"/> Installation earth electrode <input type="checkbox"/>	Type (e.g. rod(s), tape etc)	Location	Electrode resistance to earth Ω
Main Protective Conductors			
Earthing conductor:	Material <u>COPPER</u>	csa <u>16</u> mm ²	Connection / continuity verified <input checked="" type="checkbox"/>
Main protective bonding conductors (to extraneous-conductive-parts):	Material <u>COPPER</u>	csa <u>16</u> mm ²	Connection / continuity verified <input checked="" type="checkbox"/>
To water installation pipes <input checked="" type="checkbox"/>	To gas installation pipes <input type="checkbox"/>	To oil installation pipes <input type="checkbox"/>	To structural steel <input type="checkbox"/>
To lightning protection <input type="checkbox"/>	To other <input type="checkbox"/> Specify:		
Main Switch / Switch-Fuse / Circuit-Breaker / RCD			
Location	Current rating A	If RCD main switch	
BS (EN)	Fuse/device rating or setting A	Rated residual operating current ($I_{\Delta n}$) mA	
No. of poles	Voltage rating V	Rated time delay ms	
Measured operating time (at $I_{\Delta n}$) ms			

SECTION K. OBSERVATIONS

Referring to the attached Schedules of Inspection and Test Results, and subject to the limitations specified at Section D, Extent and Limitations of the Inspection and Testing: No remedial action is required The following observations are made:

Inspection Schedule Item No. or 'Test'	OBSERVATIONS	Classification Code C1, C2, C3 or FI (see below)
1.	NO RCD PROTECTION FOR a) CIRCUITS IN A ROOM CONTAINING A BATH/SHOWER b) CABLES CONCEALED IN WALLS AT A DEPTH OF LESS THAN 60mm c) SOCKET OUTLETS d) LUMINAIRES IN A DOMESTIC DWELLING	C3 C3 C3 C3
2.	KITCHEN FAN NOT WORKING	C3

One of the adjacent Codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

Danger present. Risk of injury. Immediate action required.	C1
Potentially dangerous – urgent remedial action required.	C2
Improvement recommended.	C3
Further investigation required without delay.	FI

Additional observations are recorded on the following number of continuation sheet(s)



CONDITION REPORT INSPECTION SCHEDULE (CONTINUED)

EICR 251161

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	NV	Limitation	LIM	Not applicable	N/A
ITEM No.	DESCRIPTION												OUTCOME	
													Use codes above. Provide additional comment where appropriate. C1,C2,C3 and FI coded items to be recorded in Section K of the Condition Report	
5.0 DISTRIBUTION / FINAL CIRCUITS														
5.1	Identification of conductors (Section 514)												✓	
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)												✓	
5.3	Condition of insulation of live parts (416.1)												✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1; 526.8) To include the integrity of conduit and trunking systems (metallic and plastic)												✓	
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)												✓	
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)												✓	
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)												✓	
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; Section 543)												✓	
5.9	Wiring system(s) appropriate for the type & nature of the installation & external influences (Section 522)												✓	
5.10	Concealed cables installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)												LIM	
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. <i>Extent and limitations</i>) (522.6)												LIM	
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA (415.1)													
	a) for all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)												C3	
	b) for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)												N/A	
	c) for cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)												C3	
	d) for cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)												N/A	
	e) for final circuits supplying luminaires within domestic (household) premises (411.3.4)												C3	
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)												✓	
5.14	Band II cables segregated / separated from Band I cables (528.1)												✓	
5.15	Cables segregated / separated from communications cabling (528.2)												✓	
5.16	Cables segregated / separated from non-electrical services (528.3)												✓	
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report													
	a) Connections soundly made and under no undue strain (526.6)												✓	
	b) No basic insulation of a conductor visible outside enclosure (526.8)												✓	
	c) Connections of live conductors adequately enclosed (526.5)												✓	
	d) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)												✓	
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(v))												✓	
5.19	Suitability of accessories for external influences (512.2)												✓	
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)												✓	
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)												✓	
6.0 LOCATION(S) CONTAINING A BATH OR SHOWER (SECTION 701)														
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)												C3	
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)												N/A	
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)												N/A	
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)												✓	
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)												N/A	
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)												✓	
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)												✓	
6.8	Suitability of current-using equipment for particular position within the location (701.55)												✓	
7.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS														
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)												N/A	

Inspected by: NAME (CAPITALS) Alan Bmas 2018

Signature [Signature]

Date 14/06/21
Page 4 of 5

EICR 251161

CIRCUIT CHART AND SCHEDULE OF TEST RESULTS (18 CIRCUITS)



DB Reference No. NORMAL TRANSIT OFF PEAK
 DB Location & Type HNK CARBAND

Details of circuits and/or installed equipment vulnerable to damage when testing
APPLIANCES & ELECT. APPLIANCES

Z_s at DB 0.14 Ω
 I_{nf} at DB 1.7 kA

Phase sequence confirmed (where appropriate) Correct supply polarity confirmed

CIRCUIT DETAILS										TEST RESULTS									
No.	Circuit Description	No. of Points	Wiring Details			Protective Device			Continuity			#Insulation Resistance (Lowest values measured)	Polarity	RCD Protection		Functional tests of switch-gear etc. (✓)	Remarks		
			Type (see code below)	Ref. Method	Conductor csa		Type	Amps	(R ₁ +R ₂) Ω	R _s	Ring Final Circuit			I _{Δn}	Time (ms)				
					mm ²	cpc					L-L							N-N	mA
1	NOLAN-TARLFF				6.0	4.0	4	32	0.21			99	✓						
2	COOKER				6.0	4.0	4	32	0.03			99	✓						
3	SHOWER				2.5	1.5	4	32	0.76			99	✓						
4	SOCHEDS				2.5	1.5	4	16	0.17			99	✓						
5	WHEEL-HEATER				1.5	1.0	4	5	1.23			99	✓						
6	HEATER-LIVING ROOM				2.5	1.5	4	16	0.22			99	✓						
1	OFF-PEAK																		
2	BLANK																		
3	BLANK								0.2			99							
4	BLANK																		

Code for Wiring Type		A	B	C	D	E	F	G	H	*Includes RCD and/or AFDD test button	
PVC/PVC	PVC in Metal Conduit	PVC in Plastic Conduit	PVC in Metal Trunking	PVC in Plastic Trunking	PVC/SWA	XLPE/SWA	Mineral Insulated				

TEST INSTRUMENTS USED			
Manufacturer	Type	Serial No.	Date Accuracy Verified
MEGGER	MFT 1741	1012611020612	03/21

2018	Tested by: NAME (CAPITALS)	Signature	Date
	ALAN BAINO	<i>Alan Baino</i>	14/06/21

Concise Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 14/06/2021 To: 14/06/2021

Client: David Gardiner

Site: 169 Caird St

Location: BACK BEDROOM

Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
007	Heater - Adam		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass

Location: FRONT BEDROOM

Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
008	Heater - Myson		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass

Location: HALLWAY

Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
006	Heater - Myson		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass

Location: KITCHEN

Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
001	Wahing Machine		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass
002	Fridge		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass

Location: LIVING ROOM

Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
003	Heater - Myson		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass
004	Freezer - Logik		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass
005	Tumble Dryer - Hoover		Seaward PrimeTest 350 05C-0120	14/06/2021	5 Years	14/06/2026	Pass

Total Tests: 8